

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Monitoring Requirements Not Met for Maywood Mutual Water Company #1

Our water system failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the month of September 2022, Maywood Mutual Water Company No. 1 failed to monitor general physical analytes from the distribution system and therefore, cannot be sure of the quality of our drinking water during that time.

On November 8, 2022, Maywood Mutual Water Company No. 1 received Citation No.04_16_22C_010 for Failure to Comply with Domestic Water Supply Permit Conditions for September 2022.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, and the date when samples should have been taken.

Well 4 Treatment Plant Filter Effluent

Constituent	Required sampling frequency	Number of samples taken	When all samples should have been taken	When Samples Were Taken
<u>General Physical</u>				
1. Color	One per Month	None	September 2022	October 4, 2022
2. Odor	One per Month	None	September 2022	October 4, 2022
3. Turbidity	One per Month	None	September 2022	October 4, 2022

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Permit Amendment No. 1910084PA-001 requires Maywood Mutual Water Company #1 to monitor the Well 04 Treatment Plant filter effluent monthly for color, odor, and turbidity. The analytical results shall be submitted to the Division of Drinking Water (DDW) and a summary report containing these results shall also be submitted by the tenth (10th) day of the month following the reported month to the DDW. The water system failed to monitor general physical analytes (odor, color, and turbidity) from the distribution system.

As a directive in the Citation, Maywood Mutual Water Company No. 1 was required to implement the following:

1. By July 1, 2023, MMWC1 shall notify all persons served by the water system of the violation of Permit Amendment No. 1910084-PA-001. The notification must be completed in accordance with the following:
 - a. By mail or direct delivery to each customer served by the water system;
 - b. By secondary methods such as publication in a local newspaper;
 - c. By utilizing the 2022 Consumer Confidence Report.

The Chief Operator reported that corrective action was taken by first collecting the missing samples from the Well 4 Treatment Plant filter effluent for color, odor, and turbidity on October 4, 2022. The Chief Operator also stated that a three-step approach has been created when sampling: The Sampler (1st), Chief Operator (2nd), and General Manager (3rd) must review and sign off a data sheet to ensure all required monitoring has been completed.

For more information, please contact the Chief Operator, Jose Herrera at (323) 560-2439 or mail to 5953 Gifford Ave., Huntington Park, CA 90255.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.

- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by Maywood Mutual Water Company No. 1.

State Water System ID#: 1910084.

Population Served: 5,500.

Date distributed: June 1, 2023.